

Evidence of Performance

Air permeability, Watertightness, Resistance to wind load



Test Report

No. 15-002934-PR02

(PB-A01-02-en-01)

Client EXALCO S.A.
5th Km of National Road
Larisa-Athens
41110 Larisa
Greece

Product Fixed light

Designation System designation: ALBIO 109

Performance-relevant product details Material: Aluminium profiles with thermal break

Overall dimensions (W x H) 1,105 mm x 2,200 mm

Special features Compatibility of materials must be taken into account.
Material durability must be taken into account.

Basis

EN 14351-1:2006+A1:2010

Test standard/s:

EN 1026:2000-06

EN 1027:2000-06

EN 12211:2000-06

Correspond/s to the national standard/s (e.g. DIN EN)

Representation



Results

Air permeability according to EN 12207:1999-11



Class 4

Watertightness according to EN 12208:1999-11



Class E1800

Resistance to wind load
according to EN 12210:1999-11/AC:2002-08



Class C5 / B5

Instructions for use

The manufacturer is allowed to use the results obtained for preparing a Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EC. Observe the specifications set out by the applicable product standard.

Validity

The data and results refer solely to the tested and described specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be extrapolated under the manufacturer's own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented; in particular the effects of weathering and ageing were not taken into account.

Notes on publication

The ift-Guidance Sheet "Advertising with ift test documents" applies. The cover sheet can be used as an abstract.

The report contains a total of 17 pages.

ift Rosenheim

02.10.2015

Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Construction Product Testing

Thomas Krichbaumer
Operating Testing Officer
Construction Product Testing