Evidence of Performance

Air permeability, Watertightness, Resistance to wind load

Test Report No. 15-001418-PR01

(PB-A01-02-en-01)



Client EXALCO S.A.

5th Km of National Road

Larisa-Athens 41110 Larisa Greece

Product Single tilt and turn window with fixed light at the side

Designation System designation: ALBIO 127C SUPER THERMO

Performance-relevant

product details

Material: Aluminium profiles with thermal break

Overall dimensions

 $(W \times H)$

1,400 mm x 1,400 mm

Special features Locking situation.

Results

Air permeability according to EN 12207:1999-11



Class 4

Watertightness according to EN 12208:1999-11



Class E900

Resistance to wind load according to EN 12210:1999-11/AC:2002-08



Class C4 / B4

ift Rosenheim 10.07.2015

Thomas Stefan, Dipl.-Ing. (FH) Head of Testing Department Construction Product Testing

Thomas Krichbaumer Operating Testing Officer Construction Product Testing

Thomas Krichsaumer

Basis

EN 14351-1:2006+A1:2010

Test standard/s: EN 1026:2000-06 EN 1027:2000-06 EN 12211:2000-06

Correspond/s to the national standard/s (e.g. DIN EN)

Representation



Instructions for use

The results obtained can be used by the manufacturer as the basis for the manufacturer type testing test report summary. Observe the specifications set out by the applicable product standard.

Validity

The data and results refer solely to the tested and described specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be extrapolated under the manufacturer's own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented; in particular the effects of weathering and ageing were not taken into account.

Notes on publication

The ift-Guidance Sheet "Advertising with ift test documents" applies. The cover sheet can be used as an abstract.

The report contains a total of 23 pages.

Notified Body 0757 PÜZ-Stelle: BAY 18



Ve-Prü-2087-en 01.04.2012