

Number	18-002349-PR01 (NW Z02-A01-04-en-01)
Owner	EXALCO S.A. 5th Km of National Road Larisa-Athens 41110 Larisa Greece
Product	Single-leaf tilt- and turn single window
Designation	Shipping name: ALbio 129C Advanced
Details	Manufacturer EXALCO S.A., - Larisa; Type of opening Tilt and turn; Overall dimensions (W x H) 1230 mm x 1480 mm; Rebate seal levels 3; Number of casements 1; IGU: Glass configuration LSG acoustic 12 mm / 15 mm / LSG acoustic 16 mm; Type of Gas Air; Frame member: System 129-02; Material Aluminium system with thermal break; Projected width 54.9 mm; Structural depth 69.3 mm; Casement member: System 129-14; Material Aluminium system with thermal break; Projected width 80.4 mm; Structural depth 78.3 mm

Result

Weighted Sound Reduction Index R_w and Spectrum-Adaptation Terms C and C_{tr} according to EN ISO 10140-2:2010-09, EN ISO 717-1:2013-03




$$R_w (C; C_{tr}) = 45 (-1; -5) \text{ dB}$$

Basis *)

EN ISO 10140-2:2010-09
EN ISO 717-1:2013-03
EN ISO 10140-1:2016-08
*) and corresponding national versions
e.g. DIN EN
Test report: 18-002349-PR01 PB
Z02-A01-04-en-01

Representation



Instructions for use

The results obtained can be used as evidence in accordance with the above basis.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim
10.12.2018



Dr. Joachim Hessinger, Dipl.-Phys.
Head of Testing Department
Building Acoustics



Florian Brechleier, MSc, Dipl.-Ing. (FH)
Operating Testing Officer
Building Acoustics

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: C6C-96AD8