

Classification Report

Number	18-003382-PR01 (NW-A01-0203-en-01)
Owner	EXALCO S.A. 5th Km of National Road Larisa-Athens 41110 Larisa Greece
Product	Lift-sliding door, scheme A
Designation	System: ALBIO 256 Shipping name: ALBIO 256 Thea
Details	Manufacturer EXALCO S.A., - Larisa; Material Aluminium system with thermal break; Type of opening Lifting sliding; Opening direction To the left (seen from inside); Overall dimensions (W x H) 2400 mm x 2300 mm
Special features	Increased operating forces. Internal drainage connection necessary. The vapour pressure equalisation of the glazing rebate has to be ensured. Material compatibility must be taken into account. Material durability must be taken into account. Construction with visible internal drainage.

Result

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: C4/B4

Watertightness according to EN 12208:1999-11



Class: E750

ift Rosenheim
19.11.2018



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Dimitrios Moustakidis, MSc, Dipl.-Ing.
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09
*) and corresponding national versions
e.g. DIN EN)

Test report: 18-003382-PR01 PB-A01-0203-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 211-02DF2